

NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council

DATE SAMPLES COLLECTED:

4-Nov-2025

COLLECTED BY:

M.Window

CONTACT PHONE NUMBER: 66600300

EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:

DATE SAMPLES RECEIVED:

10-Nov-25

TIME SAMPLES RECEIVED:

15:00

TECHNICAL OFFICER:

JB

DATE RESULTS Emailed to CLIENT:

10-Nov-25

DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	04/11/25		<1	<1						
	RM04 001	Casino Sextonville Rd										
2	RM04 002	Casino Showground Res	04/11/25		<1	<1						
	RM04 003	Casino 15 - 17 Sheppard St										
	RM04 004	Casino Council Depot										
3	RM04 005	Casino North Reservoir	04/11/25		<1	<1						
	RM04 006	Casino Bruton St										
4	RM04 007	Casino Walker St	04/11/25		<1	<1						
	RM04 008	Casino South Reservoir										
5	RM01 001	Coraki Memorial Park	04/11/25		<1	<1						
6	RM01 111	Box Ridge	04/11/25		<1	<1						
7	RM01 222	Broadwater Community Centre	04/11/25		<1	<1						
8	RM01 003	Rileys Hill Community Centre	04/11/25		<1	<1						
9	RM01 004	Evans Head School	04/11/25		<1	<1						
10	RM01 123	Evans High Zone	04/11/25		<1	<1						
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												