

NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council

DATE SAMPLES COLLECTED:

11-Nov-2025

COLLECTED BY:

M.Window

CONTACT PHONE NUMBER: 66600300

EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:

DATE SAMPLES RECEIVED:

11-Nov-25

TIME SAMPLES RECEIVED:

14:00

TECHNICAL OFFICER:

JB

DATE RESULTS Emailed to CLIENT:

19-Nov-25

DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries			
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature
	Site Code										
1	RM01 999	Woodburn Riverside Pk	11/11/25	8:45:00 AM	<1	<1		0.75	0.57	7.95	25.6
	RM04 001	Casino Sextonville Rd									
	RM04 002	Casino Showground Res									
2	RM04 003	Casino 15 - 17 Sheppard St	11/11/25	7:05:00 AM	<1	<1		1.07	0.62	7.85	24.8
	RM04 004	Casino Council Depot									
	RM04 005	Casino North Reservoir									
3	RM04 006	Casino Bruton St	11/11/25	7:15:00 AM	<1	<1		0.84	0.68	7.88	22.1
4	RM04 007	Casino Walker St	11/11/25	7:30:00 AM	<1	<1		0.85	0.52	7.80	27.2
	RM04 008	Casino South Reservoir									
5	RM01 001	Coraki Memorial Park	11/11/25	8:10:00 AM	<1	<1		0.86	0.73	7.96	25.9
6	RM01 111	Box Ridge	11/11/25	8:25:00 AM	<1	<1		0.84	0.66	7.98	25.3
7	RM01 222	Broadwater Community Centre	11/11/25	9:10:00 AM	<1	<1		0.97	0.83	8.06	23.6
8	RM01 003	Rileys Hill Community Centre	11/11/25	9:00:00 AM	<1	<1		0.96	0.78	8.09	24.2
9	RM01 004	Evans Head School	11/11/25	9:25:00 AM	<1	<1		1.10	0.84	8.12	25.3
10	RM01 123	Evans High Zone	11/11/25	9:35:00 AM	<1	<1		1.10	0.87	8.12	22.8
	RM01 006	Evans Reflections Caravan Park									
NHMRC Guideline - Health related											
NHMRC Guideline - Aesthetic											
Note: Health Dept data to be entered by Laboratory into Health Dept. database.											

Turbidity
0.13
0.34
0.33
0.24
0.14
0.26
0.35
0.13
0.22
0.19