NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council
DATE SAMPLES COLLECTED: 3-Feb-2026
COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300
EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:
DATE SAMPLES RECEIVED: 03-Feb-26
TIME SAMPLES RECEIVED: 14:00
TECHNICAL OFFICER: SF
DATE RESULTS Emailed to CLIENT: 05-Feb-26
DATE RESULTS Emailed to PHU: 05-Feb-26

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
	RM01 999	Woodburn Riverside Pk	03/02/26	8:45:00 AM	<1	<1		0.83	0.66	7.75	26.7	0.19
	RM04 001	Casino Sextonville Rd	-									
	RM04 002	Casino Showground Res	-									
	RM04 003	Casino 15 - 17 Sheppard St	03/02/26	7:10:00 AM	<1	<1		1.17	1.04	7.52	26.9	0.23
	RM04 004	Casino Council Depot	-									
	RM04 005	Casino North Reservoir	03/02/26	7:20:00 AM	<1	<1		1.81	1.43	7.54	26.2	0.28
	RM04 006	Casino Bruton St	-									
	RM04 007	Casino Walker St	03/02/26	7:35:00 AM	<1	<1		1.32	0.84	7.45	27.4	0.18
	RM04 008	Casino South Reservoir										
	RM01 001	Coraki Memorial Park	03/02/26	8:10:00 AM	<1	<1		0.94	0.58	7.76	29.1	0.15
	RM01 111	Box Ridge	03/02/26	8:25:00 AM	<1	<1		0.94	0.76	7.79	27.5	0.25
	RM01 222	Broadwater Community Centre	03/02/26	9:10:00 AM	<1	<1		1.36	1.04	7.80	26.0	0.24
	RM01 003	Rileys Hill Community Centre	03/02/26	8:55:00 AM	<1	<1		1.01	0.87	7.78	26.4	0.27
	RM01 004	Evans Head School	03/02/26	9:25:00 AM	<1	<1		1.08	1.00	7.79	26.1	0.22
	RM01 123	Evans High Zone	03/02/26	9:40:00 AM	<1	<1		0.64	0.46	7.81	25.1	0.18
	RM01 006	Evans Reflections Caravan Park	-									
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												

Environmental water testing in not covered by this laboratory's NATA accreditation.