NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council
DATE SAMPLES COLLECTED: 27-Jan-2026
COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300
EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:
DATE SAMPLES RECEIVED: 27-Jan-26
TIME SAMPLES RECEIVED: 14:30
TECHNICAL OFFICER: JB
DATE RESULTS Emailed to CLIENT: 31-Jan-26
DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	27/01/26	9:00:00 AM	<1	<1		0.90	0.62	7.81	29.1	0.19
2	RM04 001	Casino Sextonville Rd	27/01/26	7:50:00 AM	<1	<1		1.00	0.55	7.60	29.5	0.22
	RM04 002	Casino Showground Res										
	RM04 003	Casino 15 - 17 Sheppard St										
	RM04 004	Casino Council Depot										
	RM04 005	Casino North Reservoir										
	RM04 006	Casino Bruton St										
3	RM04 007	Casino Walker St	27/01/26	7:35:00 AM	<1	<1		1.11	0.89	7.63	28.2	0.20
	RM04 008	Casino South Reservoir										
4	RM01 001	Coraki Memorial Park	27/01/26	8:20:00 AM	<1	<1		1.05	0.95	7.81	28.7	0.15
5	RM01 111	Box Ridge	27/01/26	8:30:00 AM	<1	<1		0.90	0.71	7.85	28.5	0.25
6	RM01 222	Broadwater Community Centre	27/01/26	9:25:00 AM	<1	<1		1.03	0.85	7.91	26.7	0.14
7	RM01 003	Rileys Hill Community Centre	27/01/26	9:10:00 AM	<1	<1		1.05	0.84	7.84	27.1	0.20
8	RM01 004	Evans Head School	27/01/26	9:50:00 AM	<1	<1		1.03	0.79	7.95	27.3	0.17
9	RM01 123	Evans High Zone	27/01/26	10:15:00 AM	<1	<1		0.74	0.44	7.98	26.1	0.15
10	RM01 006	Evans Reflections Caravan Park	27/01/26	10:05:00 AM	<1	<1		0.91	0.83	7.94	27.6	0.17
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												