NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council
DATE SAMPLES COLLECTED: 25-Nov-2025
COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300
EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:
DATE SAMPLES RECEIVED: 25-Nov-25
TIME SAMPLES RECEIVED: 14:45
TECHNICAL OFFICER: JB
DATE RESULTS Emailed to CLIENT: 27-Nov-25
DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	25/11/25	8:55:00 AM	<1	<1		0.84	0.70	7.90	27.1	0.29
2	RM04 001	Casino Sextonville Rd	25/11/25	7:45:00 AM	<1	<1		0.76	0.39	7.57	27.0	0.23
	RM04 002	Casino Showground Res										
	RM04 003	Casino 15 - 17 Sheppard St										
3	RM04 004	Casino Council Depot	25/11/25	6:55:00 AM	<1	<1		0.65	0.47	7.66	25.4	0.30
	RM04 005	Casino North Reservoir										
	RM04 006	Casino Bruton St										
4	RM04 007	Casino Walker St	25/11/25	7:25:00 AM	<1	<1		1.29	0.76	7.60	25.7	0.27
	RM04 008	Casino South Reservoir										
5	RM01 001	Coraki Memorial Park	25/11/25	8:25:00 AM	<1	<1		1.06	0.80	7.98	27.0	0.28
6	RM01 111	Box Ridge	25/11/25	8:35:00 AM	<1	<1		0.94	0.74	8.01	26.5	0.25
7	RM01 222	Broadwater Community Centre	25/11/25	9:15:00 AM	<1	<1		0.96	0.72	8.01	24.4	0.22
8	RM01 003	Rileys Hill Community Centre	25/11/25	9:05:00 AM	<1	<1		0.95	0.90	7.99	23.9	0.32
9	RM01 004	Evans Head School	25/11/25	9:35:00 AM	<1	<1		1.01	0.86	8.04	26.2	0.22
10	RM01 123	Evans High Zone	25/11/25	9:50:00 AM	<1	<1		1.04	0.84	8.05	24.3	0.35
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												