NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council
DATE SAMPLES COLLECTED: 3-Mar-2026
COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300
EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:
DATE SAMPLES RECEIVED: 03-Mar-26
TIME SAMPLES RECEIVED: 13:45
TECHNICAL OFFICER: JB
DATE RESULTS Emailed to CLIENT:
DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	03/03/26	8:30:00 AM	<1	<1		0.80	0.57	7.88	27.7	0.25
2	RM04 001	Casino Sextonville Rd	03/03/26	7:25:00 AM	<1	<1		0.84	0.43	7.74	26.7	0.21
	RM04 002	Casino Showground Res										
	RM04 003	Casino 15 - 17 Sheppard St										
	RM04 004	Casino Council Depot										
3	RM04 005	Casino North Reservoir	03/03/26	7:10:00 AM	<1	<1		1.23	0.86	7.75	24.2	0.35
	RM04 006	Casino Bruton St										
4	RM04 007	Casino Walker St	03/03/26	7:30:00 AM	<1	<1		1.17	0.38	7.77	26.7	0.21
	RM04 008	Casino South Reservoir										
5	RM01 001	Coraki Memorial Park	03/03/26	8:00:00 AM	<1	<1		0.96	0.68	7.87	27.4	0.23
6	RM01 111	Box Ridge	03/03/26	8:10:00 AM	<1	<1		0.97	0.38	7.90	26.7	0.40
7	RM01 222	Broadwater Community Centre	03/03/26	8:55:00 AM	<1	<1		1.04	0.92	7.78	25.5	0.32
8	RM01 003	Rileys Hill Community Centre	03/03/26	8:45:00 AM	<1	<1		0.60	0.39	7.90	24.3	0.26
9	RM01 004	Evans Head School	03/03/26	9:15:00 AM	<1	<1		1.07	0.90	7.98	26.7	0.35
10	RM01 123	Evans High Zone	03/03/26	9:30:00 AM	<1	<1		0.60	0.46	8.03	25.7	0.33
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												