NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council
DATE SAMPLES COLLECTED: 5-May-2026
COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300
EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:
DATE SAMPLES RECEIVED: 05-May-26
TIME SAMPLES RECEIVED: 12:55
TECHNICAL OFFICER: JB
DATE RESULTS Emailed to CLIENT: 11-May-26
DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02		*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	winLIMS	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	05/05/26	8:35:00 AM	<1	<1	2026006123	0.73	0.46	7.92	22.8	0.31
	RM04 001	Casino Sextonville Rd										
	RM04 002	Casino Showground Res										
2	RM04 003	Casino 15 - 17 Sheppard St	05/05/26	7:10:00 AM	<1	<1	2026006124	1.03	0.93	7.70	23.3	0.20
	RM04 004	Casino Council Depot										
3	RM04 005	Casino North Reservoir	05/05/26	7:20:00 AM	<1	<1	2026006134	1.22	0.90	7.72	20.7	0.30
	RM04 006	Casino Bruton St										
4	RM04 007	Casino Walker St	05/05/26	7:35:00 AM	<1	<1	2026006135	1.09	0.78	7.74	22.6	0.22
	RM04 008	Casino South Reservoir										
5	RM01 001	Coraki Memorial Park	05/05/26	8:00:00 AM	<1	<1	2026006136	0.81	0.66	7.87	23.7	0.25
6	RM01 111	Box Ridge	05/05/26	8:15:00 AM	<1	<1	2026006125	0.80	0.58	7.90	22.8	0.28
7	RM01 222	Broadwater Community Centre	05/05/26	9:05:00 AM	<1	<1	2026006137	0.73	0.58	7.90	22.4	0.20
8	RM01 003	Rileys Hill Community Centre	05/05/26	8:50:00 AM	<1	<1	2026006138	0.67	0.39	7.83	22.2	0.22
9	RM01 004	Evans Head School	05/05/26	9:30:00 AM	<1	<1	2026006126	0.80	0.56	7.89	23.2	0.19
10	RM01 123	Evans High Zone	05/05/26	9:45:00 AM	<1	<1	2026006139	0.64	0.31	8.00	22.3	0.24
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												

Environmental water testing in not covered by this laboratory's NATA accreditation.