NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council
DATE SAMPLES COLLECTED: 24-Mar-2026
COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300
EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:
DATE SAMPLES RECEIVED: 24-Mar-26
TIME SAMPLES RECEIVED: 14:00
TECHNICAL OFFICER: JB
DATE RESULTS Emailed to CLIENT: 27-Mar-26
DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	~~Total Plate Count cfu / ml~~	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	24/03/26	9:00:00 AM	<1	<1		0.95	0.73	7.77	26.5	0.29
	RM04 001	Casino Sextonville Rd										
	RM04 002	Casino Showground Res										
	RM04 003	Casino 15 - 17 Sheppard St										
	RM04 004	Casino Council Depot										
	RM04 005	Casino North Reservoir										
2	RM04 006	Casino Bruton St	24/03/26	7:30:00 AM	<1	<1		1.10	1.01	7.50	24.6	0.19
3	RM04 007	Casino Walker St	24/03/26	7:45:00 AM	<1	<1		1.19	0.89	7.52	25.8	0.16
4	RM04 008	Casino South Reservoir	24/03/26	8:00:00 AM	<1	<1		1.28	0.99	7.60	24.5	0.18
5	RM01 001	Coraki Memorial Park	24/03/26	8:20:00 AM	<1	<1		0.98	0.78	7.81	26.3	0.19
6	RM01 111	Box Ridge	24/03/26	8:35:00 AM	<1	<1		0.81	0.76	7.79	25.6	0.22
7	RM01 222	Broadwater Community Centre	24/03/26	9:25:00 AM	<1	<1		1.21	0.99	7.79	25.1	0.16
8	RM01 003	Rileys Hill Community Centre	24/03/26	9:10:00 AM	<1	<1		1.07	1.05	7.88	25.6	0.22
9	RM01 004	Evans Head School	24/03/26	9:45:00 AM	<1	<1		0.87	0.71	7.85	25.9	0.25
10	RM01 123	Evans High Zone	24/03/26	10:05:00 AM	<1	<1		0.49	0.39	7.83	24.9	0.31
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												

Environmental water testing in not covered by this laboratory's NATA accreditation.