NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council
DATE SAMPLES COLLECTED: 10-Mar-2026
COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300
EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:
DATE SAMPLES RECEIVED: 10-Mar-26
TIME SAMPLES RECEIVED: 13:00
TECHNICAL OFFICER: DO
DATE RESULTS Emailed to CLIENT: 12-Mar-26
DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	Total Plate Count cfu / ml	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
	RM01 999	Woodburn Riverside Pk	10/03/26	9:00:00 AM	<1	<1		0.89	0.82	7.85	27.9	0.28
	RM04 001	Casino Sextonville Rd										
	RM04 002	Casino Showground Res	10/03/26		<1	<1						
	RM04 003	Casino 15 - 17 Sheppard St										
	RM04 004	Casino Council Depot										
	RM04 005	Casino North Reservoir										
	RM04 006	Casino Bruton St										
	RM04 007	Casino Walker St	10/03/26		<1	<1						
	RM04 008	Casino South Reservoir	10/03/26	8:00:00 AM	<1	<1		1.36	1.21	7.66	25.8	0.33
	RM01 001	Coraki Memorial Park	10/03/26		<1	<1						
	RM01 111	Box Ridge	10/03/26		<1	<1						
	RM01 222	Broadwater Community Centre	10/03/26		<1	<1						
	RM01 003	Rileys Hill Community Centre	10/03/26	9:15:00 AM	<1	<1		1.19	0.97	7.84	26.2	0.22
	RM01 004	Evans Head School	10/03/26	9:55:00 AM	<1	<1		1.06	0.87	7.88	26.3	0.23
	RM01 123	Evans High Zone	10/03/26		<1	<1						
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												