NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council
DATE SAMPLES COLLECTED: 17-Mar-2026
COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300
EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:
DATE SAMPLES RECEIVED: 17-Mar-26
TIME SAMPLES RECEIVED: 13:35
TECHNICAL OFFICER: JB
DATE RESULTS Emailed to CLIENT: 23-Mar-26
DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	~~Total Plate Count cfu / ml~~	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	17/03/26	8:40:00 AM	<1	<1		0.62	0.45	7.79	26.6	0.14
	RM04 001	Casino Sextonville Rd										
	RM04 002	Casino Showground Res										
2	RM04 003	Casino 15 - 17 Sheppard St	17/03/26	7:00:00 AM	<1	<1		0.97	0.63	7.75	25.6	0.14
	RM04 004	Casino Council Depot										
	RM04 005	Casino North Reservoir										
	RM04 006	Casino Bruton St										
3	RM04 007	Casino Walker St	17/03/26	7:40:00 AM	<1	<1		1.08	0.77	7.70	25.7	0.27
	RM04 008	Casino South Reservoir										
4	RM01 001	Coraki Memorial Park	17/03/26	8:05:00 AM	<1	<1		0.85	0.52	7.76	27.7	0.14
5	RM01 111	Box Ridge	17/03/26	8:15:00 AM	<1	<1		0.90	0.72	7.78	26.0	0.18
6	RM01 222	Broadwater Community Centre	17/03/26	9:00:00 AM	<1	<1		1.06	0.93	7.92	24.8	0.22
7	RM01 003	Rileys Hill Community Centre	17/03/26	8:50:00 AM	<1	<1		1.04	0.86	7.85	24.8	0.22
8	RM01 004	Evans Head School	17/03/26	9:20:00 AM	<1	<1		0.90	0.84	7.90	25.8	0.31
9	RM01 123	Evans High Zone	17/03/26	9:30:00 AM	<1	<1		0.50	0.26	8.01	24.8	0.21
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												