NSW HEALTH PATHOLOGY

Ground Floor, 60 Hunter St., Lismore NSW 2480

MICROBIOLOGICAL ANALYSIS OF POTABLE WATER SAMPLES

CLIENT: Richmond Valley Council
DATE SAMPLES COLLECTED: 23-Jun-2026
COLLECTED BY: M.Window

CONTACT PHONE NUMBER: 66600300
EMAIL: allison.hawthorne@richmondvalley.nsw.gov.au

LAB NUMBER:
DATE SAMPLES RECEIVED: 23-Jun-26
TIME SAMPLES RECEIVED: 14:00
TECHNICAL OFFICER: JB
DATE RESULTS Emailed to CLIENT: 29-Jun-26
DATE RESULTS Emailed to PHU:

TEST METHOD CODES					WI01	WI02	WMF03	*On site Chemistries				
Marked	Sampling point		Date	Time	Total Coliforms mpn / 100ml	E.coli mpn / 100ml	winLIMS	Total Chlorine	Free Chlorine	pH	Temperature	Turbidity
	Site Code											
1	RM01 999	Woodburn Riverside Pk	23/06/26	8:45:00 AM	<1	<1	2026008646	0.88	0.79	7.92	18.8	0.26
	RM04 001	Casino Sextonville Rd										
	RM04 002	Casino Showground Res										
	RM04 003	Casino 15 - 17 Sheppard St										
2	RM04 004	Casino Council Depot	23/06/26	7:05:00 AM	<1	<1	2026008647	0.71	0.56	7.72	17.7	0.26
	RM04 005	Casino North Reservoir										
3	RM04 006	Casino Bruton St	23/06/26	7:30:00 AM	<1	<1	2026008648	1.03	0.83	7.60	17.5	0.19
4	RM04 007	Casino Walker St	23/06/26	7:50:00 AM	<1	<1	2026008652	1.04	0.71	7.62	17.9	0.21
	RM04 008	Casino South Reservoir										
5	RM01 001	Coraki Memorial Park	23/06/26	8:10:00 AM	<1	<1	2026008649	1.19	1.02	7.77	19.5	0.24
6	RM01 111	Box Ridge	23/06/26	8:25:00 AM	<1	<1	2026008653	1.11	1.03	7.85	19.1	0.28
7	RM01 222	Broadwater Community Centre	23/06/26	9:10:00 AM	<1	<1	2026008650	0.78	0.67	7.83	18.5	0.22
8	RM01 003	Rileys Hill Community Centre	23/06/26	8:55:00 AM	<1	<1	2026008654	1.04	0.83	7.94	18.3	0.24
9	RM01 004	Evans Head School	23/06/26	9:25:00 AM	<1	<1	2026008655	1.05	1.00	7.88	19.0	0.21
10	RM01 123	Evans High Zone	23/06/26	9:45:00 AM	<1	<1	2026008651	0.84	0.81	7.79	18.4	0.22
	RM01 006	Evans Reflections Caravan Park										
NHMRC Guideline - Health related												
NHMRC Guideline - Aesthetic												
Note: Health Dept data to be entered by Laboratory into Health Dept. database.												

Environmental water testing in not covered by this laboratory's NATA accreditation.